

CERTIFICATE OF COMPLIANCE

Certificate Number 20181031-E201573
Report Reference E201573-20060427
Issue Date 2018-OCTOBER-31

Issued to: WAGO Kontakttechnik GmbH & Co. KG
Hansastrasse 27
32423 Minden GERMANY

**This is to certify that
representative samples of**

GROUNDING AND BONDING EQUIPMENT
Listed Spring Action Grounding wire connectors, Cat. Nos.
222-412 through 222-415, & 222-462 through 222-468. Cat.
Nos. 221-412, 221-413, 221-415. Cat. Nos. 221-612, 221-
613, 221-615.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Grounding and Bonding Equipment, UL 467 and CAN/CSA
C22.2 No. 41-13.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



File E201573
Project 06CA17068

April 27, 2006

REPORT

on

GROUNDING AND BONDING EQUIPMENT

Wago Kontakttechnik GmbH
Minden, Fed Rep Germany

Copyright © 2006 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above-named company to reproduce this Report provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

*USL, CNL - Listed Spring Action Grounding wire connectors, Cat. Nos. 222-412 through 222-415, & 222-462 through 222-468. Cat. Nos. **221-412, 221-413, 221-415**. Cat. Nos. 221-612, 221-613, 221-615.

GENERAL CHARACTER AND USE:

Type of Wiring Termination: Spring Action

USL - Compliance to UL 467, Grounding and Bonding Equipment

CNL - Compliance to CSA C22.2 No.41-13, Grounding and Bonding Equipment

Ratings:

Cat. Nos.	Wire Range AWG Cu
222-412 through 222-415, & 222-462 through 222-468	Nos. 28-12 Sol/Str
221-412, 221-413, 221-415	Nos. 24-12 Sol/Str
221-612, 221-613, 221-615	Nos. 20-10 Sol/Str

The insulating cover described in this Report are molded from a Recognized Component plastic (QMFZ2), in two pieces and provided with Operating Leaver.

Insulating Materials - The following Recognized Component plastic (QMFZ2) materials are used for the Cat. Nos. specified below.

Series	Material designation and manufacture	Insulating Material Temperature °C
222		105
		105
		130
221 (Housing)		105
221 (Lever)		105

SERIES 222 NOMENCLATURE:

$\frac{222}{A}$	$\frac{-46}{B}$	$\frac{3}{C}$
-----------------	-----------------	---------------

A. Basic Type - Series 222

B. Model Color -
-46 - Green
-41 - GreyC. Number of Poles
2 - 2 Poles
3 - 3 Poles
4 - 4 Poles
5 - 5 Poles
6 - 6 Poles
7 - 7 Poles
8 - 8 Poles**SERIES 221 NOMENCLATURE:**

$\frac{221}{A}$	$\frac{-41}{B}$	$\frac{3}{C}$
-----------------	-----------------	---------------

A. Basic Type - Series 221

*B. Model Color-

41 or 61 - Transparent
C. Number of Poles
2 - Poles
3 - Poles
5 - Poles