



## Pump Genius Multipump V2.00 Application Information

Equipment: CFW500

Firmware Version: V1.50 or higher

WLP Software Version: V10.00 or higher

New Application Version: PGMPM\_CFW500\_en\_V2\_00.apl

Old Application Version: MPSD\_CFW500\_en-1\_05.apl

Document Number (Application Manual): 10004314066 / 00

### Functional deviations in the old application version

- 1) There is not

### Changes in the new application version

- 1) It was implemented a new layout for Configuration Wizards and Monitoring Dialogs;
- 2) It was changed the sequence of application User's Parameters for Pump Genius Multipump;
- 3) It was changed the control variable type of the functions Sleep Mode, Start one Parallel Pump and Stop a Parallel Pump, from "PID Controller Output (in %)" to "Pump Speed (in Hz)".



**NOTE!**

Appendix 1 shows how to import Pump Genius Multipump application to WLP.

## Appendix 1 – How to Import Application to WLP

- 1) In the WLP Ladder Programmer, in “Tools” menu, select the “Import Application to WLP” option;
- 2) Search “PGMPM\_CFW500\_en\_V2\_00.apl” archive and press “OK”;
- 3) The Pump Genius Multipump application will be imported to WLP;
- 4) To select the application, in “Tools” menu, “Application” option, “CFW500”, “Create”, “Pump Genius”, select “Multipump” option.